CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0075:188 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Fire-Lite Alarms, Inc., One Fire-Lite Place, Northford CT 06472-1653

Contact: Brian Reynolds (203) 484-1200

DESIGN: Model MS-2410B fire alarm control unit. Local and remote station, noncoded,

automatic, manual, waterflow and sprinkler supervisory service. Refer to listee's data

sheet for detailed product description and operational considerations. System

components:

MS-2410B Control Unit LFD-10IM LFD-10 Interface

DP-2410B Press Plate For Control Unit

4XTMF Transmitter Module

XRM-24 Transformer

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a fire alarm control unit for use with separately listed compatible initiating and

indicating devices.

This control unit can generate the temporal code pattern fire alarm signal as required per

NFPA 72, 1996 Edition. Refer to manufacturer's Installation Manual for details.

NOTE: For Fire Alarm Verification feature (delay of fire alarm), the retard/reset/restart period

shall not exceed 30 seconds.

11-27-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

APRIL 10, 2002 Date Issued: Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager